

# MAHARASHTRA POLLUTION CONTROL BOARD

Tel.No. (0240) 2993004



"Your Service is our Duty"

Regional Office, Paryavaran Bhavan,  
A-4/1, MIDC Area, Chikalthana,  
Behind Daynik Lokpatra, Near Seth  
Nandlal Dhoot Hospital, Jalna Road,  
Aurangabad-431 210.

**By FAX/R.P.A.D./HAND DELIVERY:**

No. MPCB/ROA/PD/ 2305-300001/2023

Date: - 30/05/2023

To,

M/s. NRB Bearings Ltd  
Plot No. - B-18, MIDC Shendra,  
Dist. Aurangabad.

**Sub: Proposed Directions u/s 33A of the Water (Prevention & Control of Pollution) Act, 1974 and u/s 31A of the Air (Prevention & Control of Pollution) Act, 1981.**

**Ref:** 1) Consent granted by the Board.  
2) Visit of undersigned to your unit on 19/04/2022.

WHEREAS your industry is located in the "Pollution Prevention Area" under the Water (Prevention & Control of Pollution) Act, 1974, under the Air (Prevention & Control of Pollution) Act, 1981 and Hazardous & Other Wastes (Management & Transboundary Movement) Rules, 2016 and followed by further amendments made therein from time to time.

AND WHEREAS it is obligatory on your part to comply with the conditions of consent issued under Section 26 of the Water (Prevention & Control of Pollution) Act, 1974, under Section 21 of the Air (Prevention & Control of Pollution) Act, 1981 and Authorization under Rule 5 of the Hazardous & Other Wastes (Management & Transboundary Movement) Rules, 2016 and amendments thereof. And it is obligatory on your part to provide pollution control system as it warranted and to operate and maintain the same continuously and effectively so as to achieve the standards prescribed in the Consent.

AND WHEREAS the undersigned visited your unit on 19/04/2022 to check compliance under the environment acts.

1. Existing existing BG of Rs, 5 lakhs which is valid up to 7.4.2023 is forfeited as per new consent conditions however the records of the same not available during visit.
2. Two new Bank Gurantee of Rs.10.0 lakh, against and OAndM and 10 lakh against providing ZLD which is not submitted.
3. Also PP not installed ZLD system to achieve ZLD.
4. During visit JVS of combine treated effluent from ETP and STP outlet is collected in presence of industry representative.
5. The treatment tanks found full of oily layer which needs to be removed.

AND WHEREAS from the record of this office and the observations made during the visit, I came to the conclusion that you are not complying with the consent conditions and the provisions of Water (Prevention & Control of Pollution) Act, 1974 and the Air (Prevention & Control of Pollution) Act, 1981 thereby causing grave injury to the environment.

NOW THEREFORE in exercise of the powers conferred upon me under Section 33A of the Water (Prevention & Control of Pollution) Act, 1974 and under Section 31A of the Air (Prevention & Control of Pollution) Act, 1981, I, Dilip Khedkar, Regional Officer of the Board at Aurangabad hereby issue proposed directions as under:

1. Why your industry shall not be directed to close down its activity forthwith?
2. Why the competent authority shall not be directed to disconnect water/electricity supply of your unit?
3. Why prosecution shall not be filed in the court of law and environmental compensation shall not be recovered from you?

You are directed to submit your reply forth with in respect of above related points/non-compliances along with all necessary documents, photographs to this office, failing of which further necessary action as deem fit in your case as per the provisions of various environmental enactments will be initiated against you, which may please be noted.

FOR & ON BEHALF OF THE BOARD,



(Dilip Khedkar)

Regional Officer - Aurangabad

Copy submitted to:

1. The Joint Director (APC), MPCB, Mumbai.
2. The Law Officer (P & L Div), MPCB, Mumbai.

Copy for information and necessary follow-up action to:

1. The Sub-Regional Officer, MPCB, Aurangabad - for information and to report the compliance accordingly.