

# MAHARASHTRA POLLUTION CONTROL BOARD REGIONAL OFFICE-KALYAN

Tel. No. (0251) 2310167/2310212

Fax No. (0251) 2310192

Visit us on: <http://mpcb.gov.in>

E-mail: [rokalyan@mpcb.gov.in](mailto:rokalyan@mpcb.gov.in)



"Your Service is our Duty"

Siddhivinayak Sankul,  
3<sup>rd</sup> Floor, Near Oak Baug,  
Station Road,  
Kalyan (West)-421 301.

No. MPCB/CD/ 2504070002  
Email / Hand Delivery / RPAD

Date :- 07/04/2025

To,  
**M/s. Surat District Co-Operative Milk Producers' Union Ltd,**  
**Gut No. 205, National Highway No. 3,**  
**Vill. Lahe, Tal. Shahapur, Dist. Thane.**

**Sub :-** Closure Directions u/s 33A of the Water (Prevention & Control of Pollution) Act, 1974 and u/s 31A of the Air (Prevention & Control of Pollution) Act, 1981.

- Ref :-**
- 1) Consent granted by the MPC Board dtd. 08/07/2020.
  - 2) Interim Directions issued by the Board on 09/01/2025.
  - 3) Legal action proposal No. MPCB-LEGAL\_ACTIONS-020125017.
  - 4) Personal hearing extended on 13/03/2025.
  - 5) Approval of competent authority of the MPC Board dtd. 03/04/2025.

.....  
**WHEREAS,** the Maharashtra Pollution Control Board has granted Consent to Establish/Operate u/s 25/26 of the Water (Prevention and Control of Pollution) Act, 1974 and u/s 21 of the Air (Prevention and Control of Pollution) Act, 1981 & Authorization under Rule 6 of the Hazardous and Other Wastes (Management and Trans-boundary Movement) Rules, 2016, subject to certain terms and conditions.

**AND WHEREAS,** it was also obligatory on your part to provide adequate and efficient pollution control devices and take adequate measures to control air & water pollution, so as to achieve the consented standards.


**AND WHEREAS,** Maharashtra Pollution Control Board had issued Interim Directions to the unit on 09/01/2025. **AND WHEREAS,** the personal hearing extended on 13/03/2025 and Hon'ble Member Secretary directed that, to issue safe closure directions towards the non-compliance of consent conditions.

- 1) You have not upgraded existing effluent treatment plant (ETP) as per interim directions dtd. 09/01/2025.
- 2) You are not operating effluent treatment plant (ETP) properly.
- 3) You are not operating UF-RO regularly.
- 4) You have not provided flow meter at ETP inlet and outlet.
- 5) You have not disposed treated effluent as per consent conditions no. 4(1).
- 6) You have not obtained CGWA NOC for ground water extraction.
- 7) You have not provided separate energy meter to pollution control devices.

**AND WHEREAS,** in spite of giving reasonable opportunity, after examining the record of your case and the reports of the officers of the Board, it has been observed that you have not complied with consent conditions and Interim Directions and causing Air pollution problems in the surrounding area knowingly and willfully.

**NOW THEREFORE**, in view of the above non-compliances, you are hereby directed to stop your manufacturing activity taking all precautionary measures for safe closure of the unit within 72 hours from receipt of this direction, failing which, the Board will have no option than to initiate appropriate legal action under the provisions of the Water (Prevention & Control of Pollution) Act, 1974 and the Air (Prevention & Control of Pollution) Act, 1981.

This is issued with the approval of competent authority of the MPC Board.

  
**Dr. R. A. Rajput**  
**Regional Officer, Kalyan**

**Copy submitted for information to:**

The Member Secretary, M.P.C. Board, Mumbai.

**Copy f.w.cs to:**

- 1) Regional Officer (BMW), M.P.C. Board, Mumbai.
- 2) Law Officer, MPC Board, Mumbai.

**Copy f.w.cs to:**

- 1) Ex. Engineer / Addl. Engineer / Sub Divisional Engineer / Deputy Engineer, Maharashtra State Electricity Distribution Co. Ltd., Vill Lahe, Tal. Shahapur, Dist. Thane – It is directed to disconnect electricity supply to the aforesaid unit after completion of 72 hours for safe closure of the unit & inform this office accordingly.
- 2) Grampanchayat Lahe, Vill Lahe, Tal. Shahapur, Dist. Thane - It is directed to disconnect water supply to the aforesaid unit after completion of 72 hours for safe closure of the unit & inform this office accordingly

**Copy to:** Sub Regional Officer, MPC Board, Kalyan-3– It is directed to take follow up and ensure the compliance of the aforesaid directions. It is also directed to ensure that these Directions to be served to the industry and competent authorities & submit the compliance verification report.