

**MAHARASHTRA POLLUTION CONTROL BOARD
REGIONAL OFFICE, KOLHAPUR.**

Tel. No. (0231) 2652952,
2660448
Fax No. (0231) 2652952
E-mail:
rokolhapur@mpcb.gov.in



"Your Service is Our Duty"

Udyog Bhavan,
Near Collector Office,
Kolhapur - 416 003.
Website: <http://mpcb.mah.nic.in>

No. MPCB/RO/KOP/PD/ **2404180004**

Date: **18/04/2024**

To,
M/s. Padmashri Dr D Y Patil Education Society
Medical College and Hospital and Research Centre.
E Ward, Kadamwadi,
Tal. Karveer, Dist. Kolhapur

Sub: Proposed Directions under section 33 A of Water (Prevention & Control of Pollution) Act, 1974, 31 A of Air (Prevention & Control of Pollution) Act, 1981, Hazardous Waste (M, H & T) Rules, 2008 as amended & Violation of Bio-Medical Waste (M & H) Rules, 2016.

Ref: 1. Combined Consent & Authorization for BMW Authorization Granted by the Board, vide dtd. 24/07/2023.
2. Visit of Board Officials to your HCE on 15/04/2024.
3. Approval received from HQ on 17/04/2024.

WHEREAS, the Maharashtra Pollution Control Board has granted Consent to Operate u/s 26 of the Water (Prevention and Control of Pollution) Act, 1974 and u/s 21 of the Air (Prevention and Control of Pollution) Act, 1981 and Bio-Medical Waste (M & H) Rules, 2016 & Authorization under Rule 6 of the Hazardous and Other Wastes (Management and Trans-boundary Movement) Rules, 2016, to your Health Care Establishment, which is valid up to 31.03.2028, subject to certain terms and conditions.

AND WHEREAS, it is obligatory on your part to provide adequate pollution control devices and comply with the consent conditions so as to achieve the standards prescribed by the Board in its consent.

AND WHEREAS, during surprise inspection carried out by the Board Officials on 15.04.2024 following non compliances observed: -

1. Construction work of building of proposed medical college was founding in progress without obtaining consent/permission from the Board.
2. During visit STP was not found nonfunctional, MLSS was not observed, and recirculation of return sludge were noticed.
3. You have failed to improve the Operation & Maintenance of existing combine ETP & STP.
4. You have failed to up-grad existing ETP by means of provision of primary & secondary treatment for laundry effluent.

...2...


AND WHEREAS it has been observed that you have failed to comply with the conditions stipulated in Combine Consent for BMW Authorization granted by the Board and thereby violating the Environment enactments.

NOW THEREFORE, in view of the above non-compliance, you are hereby directed to show cause as to:

1. Why your CCA combined consent & authorization shall not be revoked? along with the forfeiture of Bank Guarantee?
2. Why your HCE activities shall not be closed?
3. Why the competent Authorities shall not be directed to disconnect water / electricity supply to your HCE?

You are hereby directed to submit reply within 7 days from issuance of these directions, failing which, MPCB will initiate legal action against your HCE in accordance with the provisions of the Water (prevention & Control of Pollution) Act, 1974 and Air (Prevention & Control of Pollution) Act, 1981 & Bio Medical Waste (M & H) Rules, 2016 which please note.


This is issued with the approval of competent authority.


18.04.24
(Regional Officer)
M.P.C.B. Kolhapur

Copy submitted for information to: The Member Secretary, MPCB, Mumbai.

Copy f.w. cs.to: - Joint Director (APC) MPCB, Mumbai / Joint Director (WPC) MPCB, Mumbai, Principal Scientific Officer (PSO), MPCB, Mumbai, Law Officer (P & L Division), MPCB, Mumbai

Copy to: The Sub Regional Officer MPCB Kolhapur - He is directed to take follow up and ensure the compliance of the aforesaid directions.


18.04.24
(Regional Officer)
M.P.C.B. Kolhapur