

# MAHARASHTRA POLLUTION CONTROL BOARD

Regional Office, Kalyan

Tel: (0251) 2310167/2310212

Fax: (0251) 2310192

Website: <http://mpcb.gov.in>

E-mail: [rokalyan@mpcb.gov.in](mailto:rokalyan@mpcb.gov.in)



"Your Service is our Duty"

Siddhivinayak Sankul,  
3rd Floor, Near Oak Baug,  
Station Road,  
Kalyan (West) – 421 301.

No. MPCB/ROK/TB- 2503250002

Date: 25/03/2025

To,

M/s. Dombivli Common Effluent Treatment Plant (DCETP),  
Plot No. R-4/2, MIDC Phase-II, Opposite W-40,  
Dombivli-East, Tal.-Kalyan, Dist. Thane.

&

The Executive Engineer,  
Maharashtra Industrial Development Corporation,  
Division Dombivli, Near Pendharkar Collage,  
Dombivli-East, Dist. Thane.

**Sub :-** Directions for non-submission of compliance as per meeting conducted on 12/02/2025 at Regional Office, Kalyan.

**Ref :-** 1) Consent granted by Board vide no. Format1.0/JD(WPC)/UAN No.0000189674/CR/2405000427, dtd.07/05/2024, valid upto 31/12/2028.  
2) Show Cause Notice issued by the Board vide dtd.12/12/2024.  
3) Proposal received from Sub-Regional Officer Kalyan-I vide no. 091121010.  
4) Hon'ble Member Secretary meeting conducted on 12/02/2025.

.....

**WHEREAS**, you are operating the CETP in the pollution prevention area declared under the Provisions of the Environment Protections, Rules.

**AND WHEREAS**, it was also obligatory on your part to maintain and operate the CETP to the capacity of effluent generated from cluster of industries which are members of CETP in said area and to achieve consented parameters.

**AND WHEREAS**, Meeting was conducted before Hon'ble Member Secretary of MPCB alongwith MIDC, DCETP, DBESA and it was discussed about the segregation of effluent received from chemical industries located in MIDC Phase-I.

During discussion, MIDC official informed that they are in process to contribute 50% of the transportation cost of chemical effluent to DCETP through tankers and the rest amount will be contributed by DCETP and DEBESA (25% each). Considering your assurance made during the course of hearing, following directions are issued for immediate compliances.

- 1) The CETP shall operate and maintain all the units of the CETP round o'clock and shall achieve the disposal standards.
- 2) The CETP shall carry out the de-sludging of the inlet sump within a period of one month.
- 3) The CETP authority shall communicate the names of the defaulting industries to MPCB and MIDC.

- 4) The trade effluent of chemical Industries connected to the DBESA Textile CETP shall be segregated and transported in consultation with MIDC and DCETP within month.
- 5) D-CETP shall dedicate one tanker fitted with GPS system to lift this effluent and take it to the chemical D-CETP for further treatment and disposal. The record of the effluent generation, daily pass and receipt of effluent by each industry shall be maintained by DCETP on daily basis.
- 6) MIDC shall identify the unauthorized disposal of textile industrial effluent meeting to DCETP through CETP line immediately.
- 7) MIDC officials shall close the effluent disposal line of Defaulter industries communicated by the CETP after verification.
- 8) MIDC shall carry out the de-sludging of the final collection sump on regular basis.
- 9) The MIDC and CETP shall strictly follow the directions of lock and key arrangement.
- 10) The Bank Guarantee of Rs.2,50,000/- is forfeited from existing Bank Guarantee of Rs.10,00,000/- and shall submit top up of Bank Guarantee of Rs.10,00,000/-.

**NOW THEREFORE**, you are hereby directed to submit substantive reply / objections to these Directions within a period of 7 days, failing which, the Board will have no option than to confirm action against you, which may please be noted.



**Dr. R. A. Rajput**  
Regional Officer, Kalyan

**Copy Submitted to:**

- 1) Member Secretary, MPC Board, Sion, Mumbai.
- 2) Regional Office (BMW) MPCB Sion, Mumbai:-for information.
- 3) Law officer, MPCB Sion, Mumbai:-for information.

**Copy to:**

- 1) Sub Regional Officer, MPC Board, Kalyan-I- It is directed to submit the compliance report of the direction after verification without fail.
- 2) Master File.