

**MAHARASHTRA POLLUTION CONTROL BOARD
REGIONAL OFFICE - PUNE**

Phone No. 020-25811694
Fax No. 020-25811701
e-mail : ropune@mpcb.gov.in
visit us : www.mpcb.gov.in



Jog Centre, 3rd Floor,
Wakdewadi,
Old-Pune Mumbai Road,
Pune- 411003

MPCB/ROP/ MPCB/CD/1909110001

Date: 11/09/2019

To,
M/s. Sukhwani Construction,
Sr. No. 96/1, 97/1/1, 97/2, Vill. Tathawade,
Tal. Mulshi Dist. Pune.

Sub: Directions of Closure u/s 33-A of the Water (Prevention & Control of Pollution) Act, 1974 and u/s 31-A of the Air (Prevention & Control of Pollution) Act, 1981 r.w. Hazardous and Other Wastes (Management & Transboundary Movement) Rules, 2016.

Ref : 1. Board Official visit to your construction project dtd 26/8/2019
2. Proposal Submitted by SRO, Pimpri Chichwad dtd 29/8/2019
5. Approval to the Proposal by HQ dtd 09/9/2019

WHEREAS, your construction project is located in the "Pollution Prevention Area" under the Water (Prevention & Control of Pollution) Act 1974, under the Air (Prevention & Control of Pollution) Act 1981 and Hazardous and Other Wastes (Management and Transboundary Movement) Rules, 2016 followed by further amendments made therein from time to time.

AND WHEREAS, the Board had granted the consent to establish under Section 25 of the Water (Prevention & Control of Pollution) Act, 1974, under Section 21 of the Air (Prevention & Control of Pollution) Act, 1981 and Authorization under Rule 6 of the Hazardous Wastes (MH & TM) Rules, 2016 and amendments thereof. **ANDWHEREAS** It is mandatory to obtain consent to operate from the Board before starting of the operation activities or handing over the possession.

AND WHEREEAS, it is obligatory on your part to provide pollution control systems as it warranted and to operate and maintain the same continuously and effectively so as to achieve the standards prescribed in the consent.

AND WHEEREAS, the board officials has visited to your construction projects to check compliance of consent conditions on 26/8/2019 and Sub Regional Officer has reported following violations / non-compliances,


1. You have not obtained consent to operate from the Board for residential buildings (namely A1, B1 & C1) and given possession without obtaining consent to operate from the Board.
2. You have not operating your STP & chamber near STP was found in overflowed condition.
3. You have not provided OWC for composting of biodegradable waste.
4. You have not obtained NOC from CGWA for extraction of ground water for which you have provided 4 NOs bore-well.
5. You have not provided six month Environment Compliance report to MOEFCC & MPCB office.

AND WHEREAS, after going through the record of your case, reports and information of the Board officials and making necessary enquiries, I came to the conclusion that you are knowingly and wilfully violating the provisions of the Water (P&CP) Act, 1974 and the Air (P&CP) Act, 1981 and thereby causing grave injury to the Environment in the least bothered way.

NOW, THEREFORE, in exercise of powers conferred upon me by the Board u/s 33A of the Water (Prevention & Control of Pollution) Act, 1974 and u/s 31 A of the Air (Prevention & Control of Pollution) Act, 1981, I the undersigned, Dilip Khedkar, Regional Officer at Pune hereby direct you to stop all operating / activities being carried out in the said building within 48 Hrs. and submit compliance report to this office. Also note that, the competent authorities are directed to disconnect water and electricity supply of your Construction Project.

This is issued with approval of the Competent Authority of the Board.

For and on behalf of
Maharashtra Pollution Control Board


(Dilip Khedkar)
Regional Officer, Pune

Copy Submitted for favour of information to :

1. The Member Secretary, MPC Board, Mumbai.
2. The Joint Director (WPC), MPC Board, Mumbai.
3. Law Officer (P&L Div), MPC Board, Mumbai.


Copy forwarded with compliments for necessary action to :

1. **Executive Engineer, MSEDCL Bhosari Division, Bhosari, Pune** :- He is directed to disconnect the electric supply of above unit, after receipt of this direction and communicate accordingly.
2. **Executive Engineer, Pimpri Chinchwad Municipal Corporation, Pimpri, Pune** :- He is directed to disconnect the water supply of above unit, after receipt of this direction and communicate accordingly.

Copy to-

The Sub-Regional Officer, M.P.C.Board, Pimpri Chinchwad :- He is directed to serve this direction to the industry and report the compliance accordingly.

Maharashtra Pollution Control Board


(Dilip Khedkar)
Regional Officer, Pune