

MAHARASHTRA POLLUTION CONTROL BOARD

Regional Office, Kalyan

Tel: (0251) 2310167/2310212

Fax: (0251) 2310192

Website: <http://mpcb.gov.in>

E-mail: rokalyan@mpcb.gov.in



Siddhivinayak Sankul,
3rd Floor, Near Oak Baug,
Station Road,
Kalyan (West) – 421 301.

No. MPCB/ROK/TB- 2503250006

Date: 25/03/2025

To,

M/s. Dombivli Better Environment System Association, (DBESA CETP)
Plot No. OS-8, Opp. Savitribai Phule Natyagruh,
MIDC Phase-I, Dombivli-East, Tal.-Kalyan, Dist. Thane.

Sub :- Directions for non-submission of compliance as per meeting conducted on 12/02/2025 at Regional Office, Kalyan.

Ref :- 1) Consent granted by Board vide no. Format1.0/JD(WPC)/UAN No.0000102370/CR/2102000162, dtd.02/02/2021, valid upto 31/12/2025.
2) Proposed Directions issued by the Board vide dtd. 07/02/2024.
3) Show Cause Notice issued by the Board vide dtd.12/12/2024.
4) Proposal received from Sub-Regional Officer Kalyan-I vide no. 211219002.
5) Hon'ble Member Secretary meeting conducted on 12/02/2025.

WHEREAS, you are operating the CETP in the pollution prevention area declared under the Provisions of the Environment Protections, Rules.

AND WHEREAS, it was also obligatory on your part to maintain and operate the CETP to the capacity of effluent generated from cluster of industries which are members of CETP in said area and to achieve consented parameters.

AND WHEREAS, Meeting was conducted on 12/02/2025 before Hon'ble Member Secretary, Kalyan along with DCETP. Considering your assurance made during the course of hearing, following directions are issued for immediate compliances.

- 1) The CETP shall complete the upgradation work by June 2025.
- 2) The CETP shall operate and maintain all the units of the CETP round o'clock and shall achieve the disposal standards.
- 3) The trade effluent of Chemicals Industries connected to the DBESA Textile CETP shall be segregated.
- 4) D-CETP shall dedicated one tanker fitted with GPS system to lift this effluent and take it to the chemical D-CETP for further treatment and disposal. The record of the effluent generation, daily pass and receipt at the D-CETP shall be maintained on daily basis.
- 5) The DBESA CETP shall take effective steps for the colour removal and decide the dose of colour removal chemical on trial / pilot scale as per the quality of the trade effluent.
- 6) MIDC shall take immediate steps and find the permanent solution to avoid the ingress of the trade effluent due to overflow of the chambers.

...2

- 7) The CETP authority shall communicate the names of the defaulting industries to MPCB and MIDC.
- 8) After verification, MIDC officials shall close the disposal line of Defaulter industries communicated by the CETP.
- 9) MIDC shall carry out the desludging of final common collection sump on regular basis.
- 10) The MIDC and CETP shall strictly follow directions of lock and key arrangement.
- 11) The Bank Guarantee of Rs.2,50,000/- is forfeited from existing Bank Guarantee of Rs.5,00,000/- and shall submit top up of Bank Guarantee of Rs.5,00,000/-.

NOW THEREFORE, you are hereby directed to submit substantive reply / objections to these Directions within a period of 7 days, failing which, the Board will have no option than to confirm action against you, which may please be noted.



Dr. R. A. Rajput
Regional Officer, Kalyan

Copy Submitted to:

- 1) Member Secretary, MPC Board, Sion, Mumbai.
- 2) Regional Office (BMW) MPCB Sion, Mumbai:-for information.
- 3) Law officer, MPCB Sion, Mumbai:-for information.

Copy to:

- 1) Sub Regional Officer, MPC Board, Kalyan-I- It is directed to submit the compliance report of the direction after verification without fail.
- 2) Master File.