

MAHARASHTRA POLLUTION CONTROL BOARD

Tel : 25802272		Regional Office, Thane
Fax : 25805398		5 th Floor, Office Complex Bldg.,
Website: http://mpcb.gov.in		Near Mulund Check Naka,
E-mail Id: rothane@mpcb.gov.in		Wagle Estate, Thane-400 604.
"Your Service is our Duty"		

No: MPCB/ROT/ID/ 2302240001

Date: 24/02/2023

To,

M/s. Marson (India) Industries,
Plot No.55, Phase-1, Genesis Indl. Estate,
Kolegaon, Tal. & Dist. Palghar.

Sub:- Interim Directions under section 31 A of the Air (Prevention & Control of Pollution) Act, 1981 and under section 33 A of the Water (Prevention & Control of Pollution) Act, 1974.

- Ref:**
- 1) Show Cause Notice for closure dtd. 01/02/2023.
 - 2) Reply to Show Cause Notice dtd. 10/02/2023 received to this office during hearing on dtd 13/02/2023.
 - 3) Proposal received from SRO Tarapur-II vide Legal Unique No. MPCB- LEGAL_ACTIONS-010223004.
 - 4) Personal hearing extended to you on 13/02/2023.

This is with reference to the Show Cause Notice for closure issued by MPC Board vide above referred letter at Sr. No.1, personal hearing held before the undersigned on 13/02/2023. During the course of personal hearing your submitted reply was taken on record. You have informed about the steps being taken to comply various non-compliances mentioned in the Show Cause Notice and has also assure to take suitable action in time bound manner. Accordingly, following interim directions are issued for immediate compliance, which were also informed to you during the course of hearing.

- 1) You shall obtain renewal of consent with Zero Liquid Discharge (ZLD) immediately.
- 2) You shall operate and maintain existing Effluent treatment plant (ETP) continuously & shall recycle entire treated effluent to achieve ZLD. There shall not be any effluent discharge outside premises.
- 3) You shall submit applicable penal fees towards consent application immediately.
- 4) You shall strictly comply with consent conditions and earlier directions issued.
- 5) You shall submit Bank Guarantee of Rs. 50,000/- towards compliance of these directions within 15-days in favor of Maharashtra Pollution Control Board.

In case, you fail to comply with the above directions M.P.C. Board will have no alternative but to issue appropriate final directions to close down your industry with disconnection of Electricity / Water supply which please be note.



(R. B. Andhale)
Regional Officer, Thane

Copy submitted to:-

- 1) Member Secretary, M. P. C. Board, Mumbai.
- 2) Assistant Secretary (Technical), M.P.C. Board Mumbai.

Copy to:-

Sub-Regional Officer, M. P. C. Board, Tarapur-II - for timely follow up & verification of compliance of above directions.