

MAHARASHTRA POLLUTION CONTROL BOARD

Tel: 0240-2993004

Fax: 0240 - 2473462

Website: <http://mpcb.gov.in>

Email:

sroaurangabad1@mpcb.gov.in



Paryavaran Bhavan, A - 4/1
, MIDC Area ,
Chikalthana,Near Seth
Nandlal Dhoot Hospital ,
Jalna Road , Chatrapati
Sambhaji Nagar - 431 210

GREEN/S.S.I

Date: 08/01/2026

**No:- Format1.0/SRO/UAN No.MPCB-
CONSENT_AMMENDMENT-0000019007/CR/2601000038**

To,
M/s. BG Electricals and Electronics India Limited,
Plot No. M-137, MIDC Waluj,
Dist. Chhatrapati Sambhajinagar.



Sub: Application for grant of Consent to Amendment for change in name.

Ref: 1. Renewal of Consent to Operate granted by Board Vide No. Format1.0/SRO/UAN No.MPCBCONSENT- 0000264646/CR/2511001869 dtd. 26/11/2025.
2. Your application No. Format 1.0 / S R O / MPCB-CONSENT_AMMENDMENT-0000019007 dtd. 10.12.2025.

Your application No.MPCB-CONSENT_AMMENDMENT-0000019007 Dated 10.12.2025

For: grant of Consent to Operate under Section 26 of the Water (Prevention & Control of Pollution) Act, 1974 & under Section 21 of the Air (Prevention & Control of Pollution) Act, 1981 and Authorization under Rule 6 and Rule 18(7) of the Hazardous & Other Wastes (Management & Transboundary Movement) Rules 2016 is considered and the consent is hereby granted subject to the following terms and conditions and as detailed in the schedule I, II, III & IV annexed to this order:

- The consent to operate is granted for a period up to 31.10.2028.**
- The capital investment of the project is Rs.54.07 Crs. (As per C.A Certificate submitted by industry Existing CI is - 59.57 Crs and decrease in C.I. - Rs. 5.49 Crs)**
- Consent is valid for the manufacture of:**

Sr No	Product	Maximum Quantity	UOM
Products			
1	Relays, Flashers, Power Module	42852000	Nos./Y
2	Buzzer	3500000	Nos./Y
3	LED Lamp Assembly	2000000	Nos./Y
4	PCB Assembly - Main Controller Board - DC Charger, PCB Assembly Main Controller Board - AC Charger	1500000	Nos./Y
5	PCB Assembly - EV Charger RFID Module, PCB Assembly EV Charger GSM Module	250000	Nos./Y
6	PCB Assembly - EV Charger LED Module	250000	Nos./Y
7	Side Stand Sensors (SSS), USB Chargers	3250000	Nos./Y
8	Pressure Sensor	864000	Nos./Y
9	E-Throttle, Neutral Switches	2028000	Nos./Y
	Metal Press Components for self consumption	88200000	
	Plastic Moulded Components for self consumption	36750000	

(By using virgin Plastic/Granules as a raw material) (Without manufacturing products banned under 1. Maharashtra Plastic and Thermocol Products (Manufacturer, Usage, Sale Transport, Handling and Storage) Notification, 2018 and amendments thereof 2. Plastic Waste Management Rules, 2016 and amendments thereof) (Without use of any metal surface treatment such as Electroplating, Coating, Painting, Pickling, Heat Treatment, Foundry & without any chemical process)

4. **Conditions under Water (P&CP), 1974 Act for discharge of effluent:**

Sr No	Description	Permitted (in CMD)	Standards to	Disposal Path
1.	Trade effluent	0.8	As per Schedule - I	Recycle 100 % in the process
2.	Domestic effluent	20	As per Schedule - I	CETP

5. **Conditions under Air (P& CP) Act, 1981 for air emissions:**

Sr No.	Stack No.	Description of stack / source	Number of Stack	Standards to be achieved
1	S-1	DG Set 320 KVA	0	As per Schedule -II

6. **Non-Hazardous Wastes:**

Sr No	Type of Waste	Quantity	UoM	Treatment	Disposal
1	Metal Scrap	25	MT/M	NA	Sale to Scrap Dealer
2	Plastic Molding	25	MT/M	NA	Reuse

7. **Conditions under Hazardous & Other Wastes (M & T M) Rules 2016 for Collection, Segregation, Storage, Transportation, Treatment and Disposal of hazardous waste:**

Sr No	Category No./ Type	Quantity	UoM	Treatment	Disposal
1	5.1 Used or spent oil	30	Ltr/A	NA	Sale
2	5.2 Wastes or residues containing oil	20	Kg/Day	NA	CHWTSDF
3	33.1 Empty barrels /containers /liners contaminated with hazardous chemicals /wastes	40	No/M	NA	CHWTSDF

8. The Board reserves the right to review, amend, suspend, revoke this consent and the same shall be binding on the industry.
9. This consent should not be construed as exemption from obtaining necessary NOC/ permission from any other Government authorities.
10. The Industry shall comply with E-waste (management) Rules, 2016.
11. The Industry shall comply with Batteries (Management and Handling) Rules, 2001.
12. Industry shall comply the provisions of Maharashtra Plastic and Thermocol Items notification, 2018 and amendments thereto.
13. Industry shall comply the provisions of Plastic Waste Management Rules, 2016 and amendments thereto.
14. The industry shall obtain prior permission from Board for any addition, moderation, expansion & change in production & alteration etc.
15. Industry shall comply the provisions of Manufacture, Storage and Import of Hazardous Chemical Rules, 1989 and amended thereof.
16. Industry shall strictly carry out the production as per the activity for which you have applied application. In case during visit any variation observed the said consent will be revoked with immediate effect and Board will initiate stringent legal action against the project Proponent/Applicant.

17. The Board reserves the right to revoke change Or alter the terms and conditions of this consent.
18. The industry shall obtain necessary permission from the Directorate of Industrial Safety and Health (DISH).
19. Industry shall comply with the provisions/guidelines of Plastic Waste Management (Amendment) Rules 2022 Gazette Notification dtd-16-02-2022 issued by Ministry of Environment, Forest and Climate Change.
20. This consent to operate is having overriding effect on earlier Consent to Operate granted by the MPCB and valid No : Format1.0/SRO/UAN No.MPCBCONSENT-0000264646/CR/2511001869 dtd. 26/11/2025.
21. The applicant shall make an application for renewal of consent 120 days prior to date of expiry of the consent. (Operate/Renewal)

This consent is issued on the basis of information/documents submitted by the Applicant/Project Proponent, if it has been observed that the information submitted by the Applicant/Project Proponent is false, misleading or fraudulent, the Board reserves its right to revoke the consent & further legal action will be initiated against the Applicant/Project Proponent.



Received Consent fee of -

Sr.No	Amount(Rs.)	Transaction/DR.No.	Date	Transaction Type
1	100000.00	TXN2510004246	29/10/2025	Online Payment
2	50000.00	TXN2511000731	06/11/2025	Online Payment

Copy to:

1. Regional Officer, MPCB, Chhatrapati Sambhajinagar and Sub-Regional Officer, MPCB, Chhatrapati Sambhajinagar I
 - They are directed to ensure the compliance of the consent conditions.
2. Chief Accounts Officer, MPCB, Sion, Mumbai

SCHEDULE-I

Terms & conditions for compliance of Water Pollution Control:

1. A] As per your application, you have provided Effluent Treatment Plant (ETP) of designed capacity of 1.00 CMD consisting of Primary (Collection tank, Neutralization tank) for the treatment of 0.8 CMD of trade effluent.
- B] The Applicant shall operate the effluent treatment plant (ETP) to treat the trade effluent so as to achieve the following standards prescribed by the Board or under EP Act, 1986 and Rules made there under from time to time, whichever is stringent:

Sr.No	Parameters	Limiting concentration not to exceed in mg/l, except for pH
(1)	pH	6.0 -8.5
(2)	BOD (3 days 27°C)	30
(3)	COD	250
(4)	TSS	100
(5)	Oil & Grease	10
(6)	Phosphates as P	5
(7)	Sulphides as S	2

- C] The treated effluent shall be recycled for secondary purposes to the maximum extent and remaining shall be discharged on land for gardening within premise after confirming above standards. In no case, effluent shall find its way for gardening / outside factory premises.
2. A] The treated domestic effluent shall be soaked in a soak pit, which shall be got cleaned periodically. Overflow, if any, shall be used on land for gardening / plantation only.
- B] The Applicant shall operate the sewage treatment system to treat the sewage so as to achieve the following standards.

Sr.No	Parameters	Standards (mg/l)	
1	Suspended Solids	Not to exceed	50
2	BOD 3 days 27°C	Not to exceed	30
3	COD	Not to exceed	100

- C] The treated sewage shall be recycled for secondary purposes to the maximum extent and remaining shall be discharged on land for gardening within premise after confirming above standards. In no case, sewage shall find its way for gardening / outside factory premises.
3. The Board reserves its rights to review plans, specifications or other data relating to plant setup for the treatment of waterworks for the purification there of & the system for the disposal of sewage or trade effluent or in connection with the grant of any consent conditions. The Applicant shall obtain prior consent of the Board to take steps to establish the unit or establish any treatment and disposal system or an extension or addition thereto.
4. The industry shall ensure replacement of pollution control system or its parts after expiry of its expected life as defined by manufacturer so as to ensure the compliance of standards and safety of the operation thereof.

5. The Applicant shall comply with the provisions of the Water (Prevention & Control of Pollution) Act, 1974 and as amended, by installing water meters and other provisions as contained in the said act:

Sr. No.	Purpose for water consumed	Water consumption quantity (CMD)
1.	Industrial Cooling, spraying in mine pits or boiler feed	1.00
2.	Domestic purpose	25.00
3.	Processing whereby water gets polluted & pollutants are easily biodegradable	0.00
4.	Processing whereby water gets polluted & pollutants are not easily biodegradable and are toxic	0.00
5.	Gardening	00

6. The Applicant shall provide Specific Water Pollution control system as per the conditions of EP Act, 1986 and rule made there under from time to time/ Environmental Clearance/ CREP guidelines.



SCHEDULE-II
Terms & conditions for compliance of Air Pollution Control:

- As per your application, you have provided the Air pollution control (APC) system and erected following stack (s) to observe the following fuel pattern:

Stack No.	Source	APC System provided/proposed	Stack Height(in mtr)	Type of Fuel	Sulphur Content(in %)	Pollutant	Standard
S-1	DG Set 320 KVA		8.50	Diesel 50 --NA--	-	TPM	-
						So2	-
S-3	Moulding Fumes / Dust		7.00	Electricity 0 --NA--	-	TPM	-
S-4	Soldering Fumes /Dust		7.60	Electricity 0 --NA--	-	TPM	-
S-2	Diesel Pump		3.00	Diesel 05 --NA--	-	TPM	-

- The Applicant shall provide Specific Air Pollution control equipments as per the conditions of EP Act, 1986 and rule made there under from time to time/ Environmental Clearance / CREP guidelines.
- The applicant shall operate and maintain above mentioned air pollution control system, so as to achieve the level of pollutants to the following standards:

Parameters	Standards (unit)	
Total Particulate Matter	Not to exceed	30 mg/ Nm ³

- The Applicant shall obtain necessary prior permission for providing additional control equipment with necessary specifications and operation thereof or alteration or replacement/alteration well before its life come to an end or erection of new pollution control equipment.
- The Board reserves its rights to vary all or any of the condition in the consent, if due to any technological improvement or otherwise such variation (including the change of any control equipment, other in whole or in part is necessary).

SCHEDULE-III
Details of Bank Guarantees:

Sr. No.	Consent(C2E/C2O/C2R)	Amt of BG Imposed	Submission Period	Purpose of BG	Compliance Period	Validity Date
NA						

** The above Bank Guarantee(s) shall be submitted by the applicant in favour of Regional Officer at the respective Regional Office within 15 days of the date of issue of Consent.

Existing BG obtained for above purpose if any may be extended for period of validity as above.

BG Forfeiture History

Srno.	Consent (C2E/C2O/C2R)	Amount of BG imposed	Submission Period	Purpose of BG	Amount of BG Forfeiture	Reason of BG Forfeiture
NA						

BG Return details

Srno.	Consent (C2E/C2O/C2R)	BG imposed	Purpose of BG	Amount of BG Returned
NA				



SCHEDULE-IV
General Conditions:

1. The Energy source for lighting purpose shall preferably be LED based
2. The PP shall harvest rainwater from roof tops of the buildings and storm water drains to recharge the ground water and utilize the same for different industrial applications within the plant
3. Conditions for D.G. Set
 - a) Noise from the D.G. Set should be controlled by providing an acoustic enclosure or by treating the room acoustically.
 - b) Industry should provide acoustic enclosure for control of noise. The acoustic enclosure/ acoustic treatment of the room should be designed for minimum 25 dB (A) insertion loss or for meeting the ambient noise standards, whichever is on higher side. A suitable exhaust muffler with insertion loss of 25 dB (A) shall also be provided. The measurement of insertion loss will be done at different points at 0.5 meters from acoustic enclosure/room and then average.
 - c) Industry should make efforts to bring down noise level due to DG set, outside industrial premises, within ambient noise requirements by proper siting and control measures.
 - d) Installation of DG Set must be strictly in compliance with recommendations of DG Set manufacturer.
 - e) A proper routine and preventive maintenance procedure for DG set should be set and followed in consultation with the DG manufacturer which would help to prevent noise levels of DG set from deteriorating with use.
 - f) D.G. Set shall be operated only in case of power failure.
 - g) The applicant should not cause any nuisance in the surrounding area due to operation of D.G. Set.
 - h) The applicant shall comply with the notification of MoEFCC, India on Environment (Protection) second Amendment Rules vide GSR 371(E) dated 17.05.2002 and its amendments regarding noise limit for generator sets run with diesel.
4. The applicant shall maintain good housekeeping.
5. The non-hazardous solid waste arising in the factory premises, sweepings, etc. be disposed of scientifically so as not to cause any nuisance / pollution. The applicant shall take necessary permissions from civic authorities for disposal of solid waste.
6. The applicant shall not change or alter the quantity, quality, the rate of discharge, temperature or the mode of the effluent/emissions or hazardous wastes or control equipments provided for without previous written permission of the Board. The industry will not carry out any activity, for which this consent has not been granted/without prior consent of the Board.
7. The industry shall ensure that fugitive emissions from the activity are controlled so as to maintain clean and safe environment in and around the factory premises.
8. The industry shall submit quarterly statement in respect of industries obligation towards consent and pollution control compliance's duly supported with documentary evidences (format can downloaded from MPCB official site).
9. The industry shall submit official e-mail address and any change will be duly informed to the MPCB.
10. The industry shall achieve the National Ambient Air Quality standards prescribed vide Government of India, Notification No. B-29016/20/90/PCI-L dated. 18.11.2009 as amended.
11. The Board reserves its rights to review plans, specifications or other data relating to plant setup for the treatment of waterworks for the purification thereof & the system for the disposal of sewage or trade effluent or in connection with the grant of any consent conditions. The Applicant shall obtain prior consent of the Board to take steps to establish the unit or establish any treatment and disposal system or an extension or addition thereto.

12. The industry shall ensure replacement of pollution control system or its parts after expiry of its expected life as defined by manufacturer so as to ensure the compliance of standards and safety of the operation thereof.
13. The PP shall provide personal protection equipment as per norms of Factory Act 1948
14. Industry should monitor effluent quality, stack emissions and ambient air quality monthly/quarterly.
15. Whenever due to any accident or other unforeseen act or even, such emissions occur or is apprehended to occur in excess of standards laid down, such information shall be forthwith Reported to Board, concerned Police Station, office of Directorate of Health Services, Department of Explosives, Inspectorate of Factories and Local Body. In case of failure of pollution control equipments, the production process connected to it shall be stopped.
16. The applicant shall provide an alternate electric power source sufficient to operate all pollution control facilities installed to maintain compliance with the terms and conditions of the consent. In the absence, the applicant shall stop, reduce or otherwise, control production to abide by terms and conditions of this consent.
17. The industry shall recycle/reprocess/reuse/recover Hazardous Waste as per the provision contain in the Hazardous and Other Wastes (M & TM) Rules 2016, which can be recycled /processed /reused /recovered and only waste which has to be incinerated shall go to incineration and waste which can be used for land filling and cannot be recycled/reprocessed etc. should go for that purpose, in order to reduce load on incineration and landfill site/environment.
18. An inspection book shall be opened and made available to the Board's officers during their visit to the applicant.
19. Industry shall strictly comply with the Water (P&CP) Act, 1974, Air (P&CP) Act, 1981 and Environmental Protection Act, 1986 and industry specific standard under EP Rules 1986 which are available on MPCB website (www.mpcb.gov.in).
20. Separate drainage system shall be provided for collection of trade and sewage effluents. Terminal manholes shall be provided at the end of the collection system with arrangement for measuring the flow. No effluent shall be admitted in the pipes/sewers downstream of the terminal manholes. No effluent shall find its way other than in designed and provided collection system.
21. Neither storm water nor discharge from other premises shall be allowed to mix with the effluents from the factory.
22. The industry should not cause any nuisance in surrounding area.
23. The industry shall take adequate measures for control of noise levels from its own sources within the premises so as to maintain ambient air quality standard in respect of noise to less than 75 dB (A) during day time and 70 dB (A) during night time. Day time is reckoned in between 6 a.m. and 10 p.m. and night time is reckoned between 10 p.m. and 6 a.m.
24. The industry shall create the Environmental Cell by appointing an Environmental Engineer, Chemist and Agriculture expert for looking after day to day activities related to Environment and irrigation field where treated effluent is used for irrigation.
25. The applicant shall provide ports in the chimney(s) and facilities such as ladder, platform etc. for monitoring the air emissions and the same shall be open for inspection to/and for use of the Board's Staff. The chimney(s) vents attached to various sources of emission shall be designated by numbers such as S-1, S-2, etc. and these shall be painted/ displayed to facilitate identification.
26. The industry should comply with the Hazardous and Other Wastes (M & TM) Rules, 2016 and submit the Annual Returns as per Rule 6(5) & 20(2) of Hazardous and Other Wastes (M & TM) Rules, 2016 for the preceding year April to March in Form-IV by 30th June of every year.
27. The applicant shall install a separate meter showing the consumption of energy for operation of domestic and industrial effluent treatment plants and air pollution control system. A register showing consumption of chemicals used for treatment shall be maintained.

28. The applicant shall bring minimum 33% of the available open land under green coverage/ plantation. The applicant shall submit a yearly statement by 30th September every year on available open plot area, number of trees surviving as on 31st March of the year and number of trees planted by September end.
29. The Board reserves its rights to review plans, specifications or other data relating to plant setup for the treatment of waterworks for the purification thereof & the system for the disposal of sewage or trade effluent or in connection with the grant of any consent conditions.
30. The firm shall submit to this office, the 30th day of September every year, the Environment Statement Report for the financial year ending 31st March in the prescribed FORM-V as per the provisions of Rule 14 of the Environment (Protection) (second Amendment) Rules, 1992.
31. You shall obtain necessary prior permission for providing additional control equipment with necessary specifications and operation thereof or alteration or shall ensure replacement of pollution control system or its parts after expiry of its expected life as defined by manufacturer so as to ensure the compliance of standards and safety of the operation thereof.
32. The Board reserves its rights to vary all or any of the condition in the consent, if due to any technological improvement or otherwise such variation (including the change of any control equipment, other in whole or in part is necessary).
33. The applicant shall provide facility for collection of environmental samples and samples of trade and sewage effluents, air emissions and hazardous waste to the Board staff at the terminal or designated points and shall pay to the Board for the services rendered in this behalf.

This certificate is digitally & electronically signed.

