 Maharashtra Pollution Control Board महाराष्ट्र प्रदूषण नियंत्रण मंडळ	<h2 style="margin: 0;">Amendment of Consent</h2>	Doc. No.: QMS.P06_F02
		Revision No.: 00
		Date: 07-01-2021

MAHARASHTRA POLLUTION CONTROL BOARD

Phone : 022-27576034

Fax : 022- 27576034

Email : ronavimumbai@mpcb.gov.in



Regional Office Navi Mumbai
Raigad Bhavan, 7th Floor,
Sector-11, CBD Belapur,
Navi Mumbai - 400614



YOUR SERVICE IS OUR DUTY

Orange/MSI

No. MPCB/Amendment/Navi Mumbai/- 2303000027

Date : 16/13/2023

Sub : Amendment to the consent to operate of
M/s. ICI India Research & Technology Center.,
Plot No.1/1, TTC Industrial Area, Post Box No.12,
Thane Bealpur Road, Koparkhairane, Navi Mumbai, Dist-Thane

Ref : 1] Board's consent - RO Navi Mumbai/UAN No.89210/CR/2007001131-
Dtd 17/7/2020.
2] Industry's online application No. MPCB CONSENT_AMMENDMENT -
0000010267

Consent granted under Section 26 of the Water (Prevention & Control of Pollution) Act, 1974; under Section 21 of the Air (Prevention & Control of Pollution) Act, 1981 and Hazardous Wastes & other waste (Management and Transboundary Movement) & H) Rules, 2016 to operate the industry vide above reference No.1 is hereby amended as under:

Before read as

6. (ii) The Applicant shall erect the chimney(s) of the following specifications:

Sr.No.	Chimney attached to	Hight (meter)
1	DG Set (625 KVA)	10
2	DG Set (100 KVA)	10


Shall be read as

6. (ii) The Applicant shall erect the chimney(s) of the following specifications:

Sr.No.	Chimney attached to	Hight (meter)
1	DG Set (625 KVA)	10
2	DG Set (100 KVA)	10
1	Laboratory Spray Booth	10
2	Training Center Spray Booth	10
3	Laboratory Dust Extractor -Powder Lab	3
4	Laboratory Canopy hood and fume hood	6.5
5	Analytical Lab fume hood	6
6	Laboratory Fume Hood USIC	2

(All other conditions of the consent shall be remain unchanged.)

For & on behalf of
Maharashtra Pollution Control Board


 (D. B. Patil)

Regional Officer, Navi Mumbai



Copy to: 1) Sub-Regional Officer, Navi Mumbai-II, MPC Board, Mumbai- He is directed to serve the copy tabove said unit & submit compliance of the same time to time 2) Master file.