

# MAHARASHTRA POLLUTION CONTROL BOARD

## Sub - Regional Office - Navi Mumbai I

Phone : 022-2757 27 40  
Fax : 022-2757 1586  
Visit us at :- <http://mpcb.gov.in>  
e-mail : [sronavimumbai1@mpcb.gov.in](mailto:sronavimumbai1@mpcb.gov.in)



Raigad Bhavan,  
7th Floor, Sector-11,  
C.B.D.-Belapur  
Navi Mumbai 400 614

SRONM-I/Consent/Amendment/220517-FTS-0157/220500075 Date: 17/5/2022  
Amendment

### Subject: Amendment in the Consent...

Ref.: 1. Boards consent No: Consent No SRO NANI MUMBAI-I /CONSENT/2001001999,  
dtd. 29/01/2020.

2. Consent Amendment application no. MPCB-CONSENT- AMMENDMENT-0000007787.

The Consent to Operate as ref. no. 01 granted under Section 26 of the Water (Prevention and Control of Pollution) Act, 1974 Air (Prevention and Control of Pollution) 1981 and Authorization/Renewal of Authorization under Rule 6 of the Hazardous and Other Wastes (Management & Transboundary Movement) Rules, 2016.

As per the application made by above said industry vide ref. no. 02 that, the original consent is hereby amended as follows;

### Condition no. 05(b) shall be read as;

As per your application, you have proposed to installed the Air Pollution control (APC) System and also erected following stack(s) and to observe the following pattern.

1.	D. G. Set (320 KVA)	00	3.00	Diesel 2.5	-	00	00
----	------------------------	----	------	---------------	---	----	----

### 1. Conditions for D.G. Set

Noise from the D.G. Set should be controlled by providing an acoustic enclosure or by treating the room acoustically.

- Industry should provide acoustic enclosure for control of noise. The acoustic enclosure/ acoustic treatment of the room should be designed for minimum 25 dB (A) insertion loss or for meeting the ambient noise standards, whichever is on higher side. A suitable exhaust muffler with insertion loss of 25 dB (A) shall also be provided. The measurement of insertion loss will be done at different points at 0.5 meters from acoustic enclosure/room and then average.
- Industry should make efforts to bring down noise level due to DG set, outside industrial premises, within ambient noise requirements by proper siting and control measures.
- Installation of DG Set must be strictly in compliance with recommendations of DG Set manufacturer.
- A proper routine and preventive maintenance procedure for DG set should be set and followed in consultation with the DG manufacturer which would help to prevent noise levels of DG set from deteriorating with use.
- D.G. Set shall be operated only in case of power failure.
- The applicant should not cause any nuisance in the surrounding area due to operation of D.G. Set.
- The applicant shall comply with the notification of MoEFCC, India on Environment (Protection) second Amendment Rules vide GSR 371(E) dated 17.05.2002 and its amendments regarding noise limit for generator sets run with diesel.

All other conditions are remaining unchanged.

For & On behalf of  
Maharashtra Pollution Control Board

Sub-Regional Office, Navi Mumbai-I



To  
M/s. Pearl Metachem Pvt. Ltd.,  
Plot No. C-493, TTC Indl. Area, MIDC Pawane, Navi Mumbai.

Copy to: Regional Officer, Navi-Mumbai, M.P.C. Board, 7th Floor, Raigad Bhavan, C.B.D.-Belapur, Navi-Mumbai.