

# MAHARASHTRA POLLUTION CONTROL BOARD

Tel: 07172-272410  
Fax: 07172-272410  
Website: <http://mpcb.gov.in>  
Email:  
srochandrapur@mpcb.gov.in



Sub-Regional Office, Udyog  
Bhavan, 1st Floor, Opp. Bus  
Stand, Railway Station  
Road, Chandrapur-442401

GREEN/S.S.I (G59)

Date: 21/06/2026

No:- Format1.0/SRO/UAN No.MPCB-  
CONSENT\_AMMENDMENT-000020810/CO/2606000161

To,  
Jarawandi Mineral Stockyard of M/s Lloyds Metals &  
Energy Ltd.  
Khasara no. 59, Jarawandi, Tq. Etapali, Dist.  
Gadchiroli.



**Sub: Amendment Consent to Operate under Green Category.**

**Ref:** Consent No. SRO/UAN No.MPCB-CONSENT-0000287008/CO/2605003191 dtd  
23/05/2026 Valid upto 30/04/2029.

Your application No.MPCB-CONSENT\_AMMENDMENT-000020810 Dated 13.06.2026

For: grant of Consent to Operate under Section 26 of the Water (Prevention & Control of Pollution) Act, 1974 & under Section 21 of the Air (Prevention & Control of Pollution) Act, 1981 and Authorization under Rule 6 and Rule 18(7) of the Hazardous & Other Wastes (Management & Transboundary Movement) Rules 2016 is considered and the consent is hereby granted subject to the following terms and conditions and as detailed in the schedule I, II, III & IV annexed to this order:

- The consent to operate is granted for a period up to 30/04/2029**
- The capital investment of the project is Rs.9.50 Crs. (As per undertaking submitted by pp )**
- Consent is valid for the manufacture of:**

Sr No	Product	Maximum Quantity	UOM
Products			
1	Iron Ore (Stocking, Loading & Unloading)	150000	MT/Day

(Crushing, washing, heating, mining not allowed)

- Conditions under Water (P&CP), 1974 Act for discharge of effluent:**

Sr No	Description	Permitted (in CMD)	Standards to	Disposal Path
1.	Trade effluent	0	As per Schedule - I	Not Applicable
2.	Domestic effluent	2.0	As per Schedule - I	Soaked in soak pit

- Conditions under Air (P& CP) Act, 1981 for air emissions:**

Sr No.	Stack No.	Description of stack / source	Number of Stack	Standards to be achieved
1	1	NA	0	As per Schedule -II

6. **Non-Hazardous Wastes:**

<i>Sr No</i>	<i>Type of Waste</i>	<i>Quantity</i>	<i>UoM</i>	<i>Treatment</i>	<i>Disposal</i>
1	NA	0	--NA--	NA	NA

7. **Conditions under Hazardous & Other Wastes (M & T M) Rules 2016 for Collection, Segregation, Storage, Transportation, Treatment and Disposal of hazardous waste:**

<i>Sr No</i>	<i>Category No./ Type</i>	<i>Quantity</i>	<i>UoM</i>	<i>Treatment</i>	<i>Disposal</i>
1	5.1 Used or spent oil	3	KL/D	Disposal to MPCB and CPCB authorised vendors	Disposal to MPCB and CPCB authorised vendors

8. The Board reserves the right to review, amend, suspend, revoke this consent and the same shall be binding on the industry.
9. This consent should not be construed as exemption from obtaining necessary NOC/ permission from any other Government authorities.
10. The applicant shall make an application for renewal of consent to operate 120 days prior to the date of expiry of the consent.
11. The industry shall obtain necessary permission from the Directorate of Industrial Safety and Health (DISH)
12. The applicant shall comply with all the conditions stipulated in the Notification for mineral stock yard and Railway siding for loading & unloading of mineral & metal dtd. 26/08/2016.

This consent is issued on the basis of information/documents submitted by the Applicant/Project Proponent, if it has been observed that the information submitted by the Applicant/Project Proponent is false, misleading or fraudulent, the Board reserves its right to revoke the consent & further legal action will be initiated against the Applicant/Project Proponent.

**Received Consent fee of -**

<i>Sr.No</i>	<i>Amount(Rs.)</i>	<i>Transaction/DR.No.</i>	<i>Date</i>	<i>Transaction Type</i>
1	25000.00	MPCB-DR-42247	30/04/2026	NEFT

**Copy to:**

1. Regional Officer, MPCB, Chandrapur and Sub-Regional Officer, MPCB, Chandrapur  
- They are directed to ensure the compliance of the consent conditions.
2. Chief Accounts Officer, MPCB, Sion, Mumbai

## **SCHEDULE-I**

### **Terms & conditions for compliance of Water Pollution Control:**

1. A] Generation - As per your application the treated effluent generation is Nil.  
B] Treatment - NA  
C] Disposal - NA
2. A] NA  
B] Industry shall comply prescribed standards & disposal path as prescribed at Sr. No. 1 B & C of schedule I.
3. The Board reserves its rights to review plans, specifications or other data relating to plant setup for the treatment of waterworks for the purification there of & the system for the disposal of sewage or trade effluent or in connection with the grant of any consent conditions. The Applicant shall obtain prior consent of the Board to take steps to establish the unit or establish any treatment and disposal system or an extension or addition thereto.
4. The industry shall ensure replacement of pollution control system or its parts after expiry of its expected life as defined by manufacturer so as to ensure the compliance of standards and safety of the operation thereof.
5. The Applicant shall comply with the provisions of the Water (Prevention & Control of Pollution) Act, 1974 and as amended, by installing water meters and other provisions as contained in the said act:

<b>Sr. No.</b>	<b>Purpose for water consumed</b>	<b>Water consumption quantity (CMD)</b>
1.	Industrial Cooling, spraying in mine pits or boiler feed	80.00
2.	Domestic purpose	6.75
3.	Processing whereby water gets polluted & pollutants are easily biodegradable	0.00
4.	Processing whereby water gets polluted & pollutants are not easily biodegradable and are toxic	0.00
5.	Gardening	0

6. The Applicant shall provide Specific Water Pollution control system as per the conditions of EP Act, 1986 and rule made there under from time to time/ Environmental Clearance/ CREP guidelines.


## **SCHEDULE-II**

### **Terms & conditions for compliance of Air Pollution Control:**

1. As per your application, you have provided the Air pollution control (APC) system and erected following stack (s) to observe the following fuel pattern:

<b>Stack No.</b>	<b>Source</b>	<b>APC System provided/proposed</b>	<b>Stack Height(in mtr)</b>	<b>Type of Fuel</b>	<b>Sulphur Content(in %)</b>	<b>Pollutant</b>	<b>Standard</b>
1	NA	NA	0.00	-	-	NA	-

2. The Applicant shall provide Specific Air Pollution control equipments as per the conditions of EP Act, 1986 and rule made there under from time to time/ Environmental Clearance / CREP guidelines.
3. The Applicant shall obtain necessary prior permission for providing additional control equipment with necessary specifications and operation thereof or alteration or replacement/alteration well before its life come to an end or erection of new pollution control equipment.
4. The Board reserves its rights to vary all or any of the condition in the consent, if due to any technological improvement or otherwise such variation (including the change of any control equipment, other in whole or in part is necessary).
5. Condition under air Act
  1. The applicant shall install a comprehensive control system consisting of control equipment's as is warranted with reference to the generation of emission and operate and maintain the same continuously so as to achieve the level of pollutants to the following standards: (a) Standards for Emissions of Air Pollutants : SPM/TPM Not to exceed 100mg/Nm<sup>3</sup>
6. Control Equipment
  1. The applicant shall provide adequate air pollution control arrangements at the Source.
  2. All entry points, internal roads, and loading/unloading areas must be made road-worthy for movement of heavy vehicles by using row permeability material (e.g. concrete or bitumen) and be cleaned regularly to minimize the potential for dust generation and off-site impact.
  3. The wind-breaking wall shall be provided to the material handling area.
  4. Continuous sprinkling of water on roads and use of fogger spray at all locations of storage and handling to ensure minimum emissions.
  5. Industry shall carry out regular monitoring of ambient air quality of the nearby water bodies through MOEF approved agency and submit the report on a monthly basis to MPCB.



### SCHEDULE-III

#### Details of Bank Guarantees:

Sr. No.	Consent(C2E/C20/C2R)	Amt of BG Imposed	Submission Period	Purpose of BG	Compliance Period	Validity Date
NA						

\*\* The above Bank Guarantee(s) shall be submitted by the applicant in favour of Regional Officer at the respective Regional Office within 15 days of the date of issue of Consent.

# Existing BG obtained for above purpose if any may be extended for period of validity as above.

#### BG Forfeiture History

Srno.	Consent (C2E/C20/C2R)	Amount of BG imposed	Submission Period	Purpose of BG	Amount of BG Forfeiture	Reason of BG Forfeiture
NA						

#### BG Return details

Srno.	Consent (C2E/C20/C2R)	BG imposed	Purpose of BG	Amount of BG Returned
NA				



**SCHEDULE-IV**  
**General Conditions:**

1. The Energy source for lighting purpose shall preferably be LED based
2. The PP shall harvest rainwater from roof tops of the buildings and storm water drains to recharge the ground water and utilize the same for different industrial applications within the plant
3. Conditions for D.G. Set
  - a) Noise from the D.G. Set should be controlled by providing an acoustic enclosure or by treating the room acoustically.
  - b) Industry should provide acoustic enclosure for control of noise. The acoustic enclosure/ acoustic treatment of the room should be designed for minimum 25 dB (A) insertion loss or for meeting the ambient noise standards, whichever is on higher side. A suitable exhaust muffler with insertion loss of 25 dB (A) shall also be provided. The measurement of insertion loss will be done at different points at 0.5 meters from acoustic enclosure/room and then average.
  - c) Industry should make efforts to bring down noise level due to DG set, outside industrial premises, within ambient noise requirements by proper siting and control measures.
  - d) Installation of DG Set must be strictly in compliance with recommendations of DG Set manufacturer.
  - e) A proper routine and preventive maintenance procedure for DG set should be set and followed in consultation with the DG manufacturer which would help to prevent noise levels of DG set from deteriorating with use.
  - f) D.G. Set shall be operated only in case of power failure.
  - g) The applicant should not cause any nuisance in the surrounding area due to operation of D.G. Set.
  - h) The applicant shall comply with the notification of MoEFCC, India on Environment (Protection) second Amendment Rules vide GSR 371(E) dated 17.05.2002 and its amendments regarding noise limit for generator sets run with diesel.
4. The applicant shall maintain good housekeeping.
5. The non-hazardous solid waste arising in the factory premises, sweepings, etc. be disposed of scientifically so as not to cause any nuisance / pollution. The applicant shall take necessary permissions from civic authorities for disposal of solid waste.
6. The applicant shall not change or alter the quantity, quality, the rate of discharge, temperature or the mode of the effluent/emissions or hazardous wastes or control equipments provided for without previous written permission of the Board. The industry will not carry out any activity, for which this consent has not been granted/without prior consent of the Board.
7. The industry shall ensure that fugitive emissions from the activity are controlled so as to maintain clean and safe environment in and around the factory premises.
8. The industry shall submit quarterly statement in respect of industries obligation towards consent and pollution control compliance's duly supported with documentary evidences (format can be downloaded from MPCB official site).
9. The industry shall submit official e-mail address and any change will be duly informed to the MPCB.
10. The industry shall achieve the National Ambient Air Quality standards prescribed vide Government of India, Notification No. B-29016/20/90/PCI-L dated. 18.11.2009 as amended.
11. The Board reserves its rights to review plans, specifications or other data relating to plant setup for the treatment of waterworks for the purification thereof & the system for the disposal of sewage or trade effluent or in connection with the grant of any consent conditions. The Applicant shall obtain prior consent of the Board to take steps to establish the unit or establish any treatment and disposal system or an extension or addition thereto.

12. The industry shall ensure replacement of pollution control system or its parts after expiry of its expected life as defined by manufacturer so as to ensure the compliance of standards and safety of the operation thereof.
13. The PP shall provide personal protection equipment as per norms of Factory Act
14. Industry should monitor effluent quality, stack emissions and ambient air quality monthly/quarterly.
15. Whenever due to any accident or other unforeseen act or even, such emissions occur or is apprehended to occur in excess of standards laid down, such information shall be forthwith Reported to Board, concerned Police Station, office of Directorate of Health Services, Department of Explosives, Inspectorate of Factories and Local Body. In case of failure of pollution control equipments, the production process connected to it shall be stopped.
16. The applicant shall provide an alternate electric power source sufficient to operate all pollution control facilities installed to maintain compliance with the terms and conditions of the consent. In the absence, the applicant shall stop, reduce or otherwise, control production to abide by terms and conditions of this consent.
17. The industry shall recycle/reprocess/reuse/recover Hazardous Waste as per the provision contain in the Hazardous and Other Wastes (M & TM) Rules 2016, which can be recycled /processed /reused /recovered and only waste which has to be incinerated shall go to incineration and waste which can be used for land filling and cannot be recycled/reprocessed etc. should go for that purpose, in order to reduce load on incineration and landfill site/environment.
18. An inspection book shall be opened and made available to the Board's officers during their visit to the applicant.
19. Industry shall strictly comply with the Water (P&CP) Act, 1974, Air (P&CP) Act, 1981 and Environmental Protection Act, 1986 and industry specific standard under EP Rules 1986 which are available on MPCB website ([www.mpcb.gov.in](http://www.mpcb.gov.in)).
20. Separate drainage system shall be provided for collection of trade and sewage effluents. Terminal manholes shall be provided at the end of the collection system with arrangement for measuring the flow. No effluent shall be admitted in the pipes/sewers downstream of the terminal manholes. No effluent shall find its way other than in designed and provided collection system.
21. Neither storm water nor discharge from other premises shall be allowed to mix with the effluents from the factory.
22. The industry should not cause any nuisance in surrounding area.
23. The industry shall take adequate measures for control of noise levels from its own sources within the premises so as to maintain ambient air quality standard in respect of noise to less than 75 dB (A) during day time and 70 dB (A) during night time. Day time is reckoned in between 6 a.m. and 10 p.m. and night time is reckoned between 10 p.m. and 6 a.m.
24. The industry shall create the Environmental Cell by appointing an Environmental Engineer, Chemist and Agriculture expert for looking after day to day activities related to Environment and irrigation field where treated effluent is used for irrigation.

25. The applicant shall provide ports in the chimney/(s) and facilities such as ladder, platform etc. for monitoring the air emissions and the same shall be open for inspection to/and for use of the Board's Staff. The chimney(s) vents attached to various sources of emission shall be designated by numbers such as S-1, S-2, etc. and these shall be painted/ displayed to facilitate identification.
26. The industry should comply with the Hazardous and Other Wastes (M & TM) Rules, 2016 and submit the Annual Returns as per Rule 6(5) & 20(2) of Hazardous and Other Wastes (M & TM) Rules, 2016 for the preceding year April to March in Form-IV by 30th June of every year.
27. The applicant shall install a separate meter showing the consumption of energy for operation of domestic and industrial effluent treatment plants and air pollution control system. A register showing consumption of chemicals used for treatment shall be maintained.
28. The applicant shall bring minimum 33% of the available open land under green coverage/ plantation. The applicant shall submit a yearly statement by 30th September every year on available open plot area, number of trees surviving as on 31st March of the year and number of trees planted by September end.
29. The Board reserves its rights to review plans, specifications or other data relating to plant setup for the treatment of waterworks for the purification thereof & the system for the disposal of sewage or trade effluent or in connection with the grant of any consent conditions.
30. The firm shall submit to this office, the 30th day of September every year, the Environment Statement Report for the financial year ending 31st March in the prescribed FORM-V as per the provisions of Rule 14 of the Environment (Protection) (second Amendment) Rules, 1992.
31. The Applicant shall obtain necessary prior permission for providing additional control equipment with necessary specifications and operation thereof or alteration or replacement/alteration well before its life come to an end or erection of new pollution control equipment.
32. The Board reserves its rights to vary all or any of the condition in the consent, if due to any technological improvement or otherwise such variation (including the change of any control equipment, other in whole or in part is necessary).
33. The applicant shall provide facility for collection of environmental samples and samples of trade and sewage effluents, air emissions and hazardous waste to the Board staff at the terminal or designated points and shall pay to the Board for the services rendered in this behalf.
34. To carry out meteorological studies specifically wind directions and accordingly prepare plan to Control of fugitive emission/dust particles and suppression system.
35. A boundary wall of at least 3 meters height shall be constructed along the periphery of the mineral stack yard to prevent the fine particles from being carried away with a surface run to nearby water bodies.
36. The height of material within storage areas must be kept below the height of the boundary wall at all times to prevent the material from getting airborne.

37. Storm water drain and proper flooring shall be provided.
38. Closed for top on both sides to cover the complete railway rack with adequate ventilation/fumes extraction system.
39. On the unloading side, no discharge of excess water containing oil and particulate, etc be allowed in nearby water bodies.
40. Industry shall collect ambient air samples as per sampling protocol for RSPM parameter at 02 nearby residential location and submit a report to Board.
41. Authority shall give the undertaking to develop mechanized closed handling terminal by adopting an environmental sound system with time-bound manner.
42. Authority shall provide two lever tires washing facility at entry and exit points for vehicles.
43. Storage is done in well-demarcated compartmentalized areas and not in a haphazard manner.
44. Closed transportation system be used.
45. Strictly follow-up the MPCB Notification No.MPCB/JD(APC)Section/B-3497 dated 26 Aug 2016 Guidelines for Mineral stock yard and railway siding in the state of Maharashtra for loading/unloading of minerals and Metals.
46. This consent shall not be constructed as any exemption from obtaining necessary No Objection Certificate from any other Government Organization.

---

This certificate is digitally & electronically signed.

---

